

No : 15 / 2019
Date : 01 October 2019
Rescission Date : NA



AIRPORT EMERGENCY SERVICE

FIRE PREVENTION CIRCULAR

To All Private Developers

REQUIREMENT TO DECAM ELECTRICAL FIRE ALARM SYSTEMS TO SCDF

We will like to notify you of requirements in the **Singapore Civil Defence Force (SCDF) Fire Code 2018** (“**Fire Code 2018**”) for your immediate compliance.

2 Presently, the electrical fire alarm system(s) installed in your building(s) is connected and monitored by AES Watchroom.

3 **As per SCDF’s Fire Code 2018 regulations**, this electrical fire alarm system(s) is required to be **connected to the SCDF’s Operations Centre** through an approved alarm monitoring company.

4 This information can be found in the [SCDF Fire Code 2018](#) under Chapter 6.3 on Electrical Fire Alarm System, *para 6.3.1* and *6.3.2* (click the link to be redirected to the SCDF Fire Code).

5 All Private Developers must perform the necessary actions for your building(s) and comply with the above requirements by **31 March 2020**. Please note that after this date, AES will no longer respond to incidents at your building(s) unless such incidents impact airport operations.

6 For further clarifications, you may contact the Fire Prevention Section (FPS) of the Airport Emergency Service at 6541 2535 or e-mail to: fire.safety@changiairport.com.

A handwritten signature in black ink, appearing to be "Addison Low".

ADDISON LOW
Head, Fire Prevention Section
Airport Emergency Service